INDIAN INSTITUTE OF TECHNOLOGY MADRAS ENGINEERING UNIT

MINUTES OF THE PREBID MEETING

Name of the Work : Supplying and installing a two nos of Pressure sand filters at IIT Madras.

Tender no.

: SPS / EU/PRESSURE SAND FILTERS/002/2017-18

Date of the meeting: 05.07.2017 at 10.30 AM

: 3rd floor, Engineering Unit Conference room, Admin. Block

Members Present:

1. Er.H.Anantharaman, Superintending Engineer

2. Ms.G.Chitrapavai, Dy. Registrar (S&P)

3. Er.D.Rajavel, Asst. Exe. Engineer (WSY)

4. Er.P.Sarala, Asst. Engineer (DB)

5. Er.A.Sivakumar, Asst. Engineer (WSY)

Vendors

1. Mr.N.Shagul Ameed, M/s. IEC Fabchem Limited, Gummudipoondi.

2. Mr.G.Jayaprakash, M/s.Pure Green Engineering (P) Ltd., Chennai – 56.

Superintending Engineer extended a warm welcome to the members present in the meeting. During meeting the following points were discussed;

- 1. The discharge pump to be used during installation is as per conditions given in the tender document.
- 2. The vendor should provide a necessary provision for back washing at the exit point.
- 3. The pressure sand filter should be installed at an out door. Location will be specified before start of work.
- 4. Air scouring will be carried out by IITM.
- 5. Air release valve is shown in the tender drawing denoted by N7.

For any clarification please contact Er.D.Rajavel, Asst. Exe. Engineer (WSY), Water Supply Sub Division, Mobile: 9444395487.

Superintending Engineer