

Indian Institute of Technology Madras

Engineering Unit / Electrical Division

Tender No. 29/2013-14/ELDB

Name of the work : Provision of firm alarm, CCTV, PA system & Access control system and fire fighting system to Main, PC & FTC building for NCCRD at IIT Madras

Date : 04/11/2013

PREBID MEETING MINUTES

Part-A- Technical

1. **Eligibility criteria:** At least one work should be from Government that includes state government also. Proof of completion should be attached from an officer not lower than the rank of Executive Engineer.
2. Latest solvency certificate in the specified form from the Bank is acceptable.
3. Separate sheet can be used wherever necessary to submit the required details.
4. Payment terms: 70 % against delivery at site, 20 % against installation and 10 % against testing, commissioning & handing over of the system.
5. The contractor should submit the FORM A in the specified format for last 3 years certified by a Chartered Accountant.
6. The contract period may be read as year ending March 2013 instead of March 2010.

Part- B- Commercial

1. Item No. Part-A/A8, B12, B13, C17, D24, D25 & Part-B/A31 & B34 may be read as wiring in the existing MS/PVC conduits.
2. Part D-Item No.18 2 reader controllers can be chosen if 4 reader controller is not available in the market.
3. RS485/422 telemetry of Digital recorder may be considered as either RS485 or RS422.
4. LG make can be used for cameras at par with DVR. The video camera of either CE or CUG is acceptable.
5. The storage of Digital recorder shall be considered as internal HDD up to 4 SATA 16 TB storage supported.
6. The resettable emergency release box can be chosen from any other reputed make if the proposed makes are not available in the market. However, the contractor should propose the same at the time of submission of tender.
7. Siemens products may also be considered wherever it is applicable.
8. Item No.D19 & D20 of BOQ may be read as Proximity reader instead of HID Proximity reader.
9. Any one make of loud speakers may be chosen from the list of make prescribed in the BOQ according to their specification (the memory capacity shall be 15-20MB).
10. No changes in both commercial & technical bids.

**Sd-
Consultant (Electrical)**

Sd-

Executive Engineer (E)