

INDIAN INSTITUTE OF TECHNOLOGY MADRAS
ENGINEERING UNIT

MINUTES OF THE PRE BID MEETING WITH CONTRACTORS



Name of work : Addition and Alteration works at Institute and Workshop buildings in Academic Zone for the year 2013-14.

Reference : T.No 74 / 2012-13 / Civil

Date of meeting: 21.02.2013 at 10:30 AM

Venue: Engineering Unit Conference room, Administrative Building 3rd floor

Members Present:

IIT MADRAS	CONTRACTORS
Er.L.Venkataraman, Executive Engineer (Civil) Dr.M.Ramachandran, EE,i/c (Civil) Er. A. Siva Kumar, JE (DB)	Shri.S.Paulraj., DGM, M/s RR Thulasi Builders Shri.K.Murugantham, M/s GMS Elegant Builders (I) pvt Ltd.,

The following points were discussed and the decisions taken against each.

S No	Points raised	Clarification sought
1	Whether the water will be supplied by the Institute or not?	Yes, Water will be supplied by the Institute at the rate of 1.5% of the bill value.
2	Request for Labour camp	No labour camp will be permitted inside the campus.
3	Requested for Mobilization Advance.	It is explained that no Mobilization advance will be paid.
4	Cover 2 /page 129/ Item No 45. Whether Fly ash to be added in the RCC or not?	Yes. The item shall be read as Providing and laying in position of RCC of grade M35 Concrete with super plasticizers for walls and floors, columns, beams and slabs excluding cost of centering, shuttering, finishing and reinforcement etc complete at all levels as per the direction of Engineer in charge.(minimum cement content 380 kg/cum) and 50 kg of Fly ash to be added.

5	<p>Cover 2 /page 144/ Item No 134</p> <p>Size of the Notice Board Not mentioned in the specification?</p>	<p>The item shall be read as</p> <p>Providing and fixing of Notice Board of size 1.20m x 0.90m using 19mm thick plywood all-round frame and fixing of mica lamination on all exposed surfaces and 12mm thick BWR waterproof ply (Kitply / Century ply) .</p>
6	<p>Cover 2 /page 156/ Item No 210</p> <p>For shutters of doors, windows and ventilators including providing and fixing hinges / pivots and making provision for fixing of fittings wherever required including the cost of PVC /neoprene gasket required. Including Fittings or approved make as per the instruction of Engineer-in-charge.</p>	<p>The item shall be read as</p> <p>For shutters of doors, windows and ventilators including providing and fixing hinges / pivots and making provision for fixing of fittings wherever required including the cost of PVC /neoprene gasket required. Excluding the cost of fittings as per the instruction of Engineer-in-charge.</p>

The above minutes of meeting will become part of the agreement.


Executive Engineer (Civil) i/c


Co-Chairman (EU)


Executive Engineer (Civil)